

Draft Stage 1 Update on Geotech: James Griffiths (Beca) gave a presentation on historical information and assumptions made on that basis (noting this is the first stage of the geotech review and more information won't be available until after a few months of monitoring). Key takeaways were:

- Eastern end is most likely non engineered fill and would not meet modern standards for building on.
- 1960s site was earth worked and then pool constructed 5 years later.
- The past is a clue to the future and on that basis likely that the settlement continues, with limited options to remediate if required and is unlikely to be economical.
- The draft Stage 1 geotech report is with the working group for feedback.
- Beca is going to provide the working group with a proposal for next steps to ensure the working group has all the information to aid recommendations to Council.